Summary of Asset Failures by Location

Location: BR430
Description: Condensate Return Pump- Centrifugal/100GPM/60FTHD
Site: BEDFORD
Start Date: 1/1/95
End Date: 1/1/05

Summary of Asset Failures by Location

Summary of Asset Failures by Location

Asset	Description	Mfr	Install Date	Warranty Date	Failure Class	# Failures	MTBF (Days)	Avg Downtime During Failures (Hrs)	Avg Downtime All (Hrs)
11430	Pump,Centrifugal, 2.5, 3, 100.0, 60.0 FtHd, 45, 1,200.0 RPM, Direct	IR	4/7/95	1/29/11	PUMPS	22	86.55	1.84	1.23